

PWSID:	NJ1918352	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	SUSSEX CTY CHARTER SCHOOL - B	System Status:	A

Lead/Copper Results for Compliance Period: 01/01/2017--12/31/2019

Lead

5 Samples; 90th %ile: 0.00762 MG/L

Copper

5 Samples; 90th %ile: 0.323 MG/L

Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received	Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received
06/11/2019	DS	19060612-01	8.61 UG/L	06/18/2019	07/11/2019	06/11/2019	DS	19060612-01	0.163 MG/L	06/18/2019	07/11/2019
06/11/2019	DS	19060612-02	6.62 UG/L	06/18/2019	07/11/2019	06/11/2019	DS	19060612-02	0.171 MG/L	06/18/2019	07/11/2019
06/11/2019	DS	19060612-03	5.37 UG/L	06/18/2019	07/11/2019	06/11/2019	DS	19060612-03	0.202 MG/L	06/18/2019	07/11/2019
06/11/2019	DS	19060612-04	<2 UG/L	06/18/2019	07/11/2019	06/11/2019	DS	19060612-04	0.346 MG/L	06/18/2019	07/11/2019
06/11/2019	DS	19060612-05	<2 UG/L	06/18/2019	07/11/2019	06/11/2019	DS	19060612-05	0.299 MG/L	06/18/2019	07/11/2019

^Rollover sample # to see lab name and ID and METHOD

*MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).

µg/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).

pCi/L=picocuries of contaminant per liter of water--a curie is a measurement of the rate at which a radioactive material decays.

"<" (less than) means the contaminant cannot be accurately detected below the limit specified; the result can be considered zero.